



Farabaugh Engineering and Testing Inc.

Date: June 20, 2012

PERFORMANCE TEST SUMMARY

ASTM B117-09
Standard Practice for Operating Salt Spray (Fog) Apparatus
for
Lifetime Tool and Building Products
250 AIRPORT ROAD
WINCHESTER, VA 22602

Purpose


The purpose of this testing of Lifetime Tool and Building Products' "*Ultimate Pipe Flashing*" in accordance with the following testing standards:

- 1.) Corrosion resistance in a controlled corrosive environment in accordance with ASTM B-117-09 "Standard Practice for Operating Salt Spray (Fog) Apparatus"

Ultimate Pipe Flashing Materials: -Kynar® PVDF coated 24 gauge galvanized sheet steel
-Ultra-pure high consistency molded silicone rubber
-UV stable solid molded PVC compound

Test Summary

Thus far Lifetime Tool and Building Products' "*Ultimate Pipe Flashing*" has completed 120 hours with no rust observed.



Daniel G. Farabaugh, President
Farabaugh Engineering and Testing Inc.

